

June 27, 2006

INTERNATIONAL PRODUCTION SPECIALISTS
JAY BANDHOLZ
35006 WASHINGTON AVE
PO BOX 125
HONEY CREEK WI 53138

Re: Description: SEWAGE TANKS, STEEL
Manufacturer: INTERNATIONAL PRODUCTION SPECIALISTS
Product Name: SEPTIC, PUMP OR HOLDING
Model Number(s): 2500/H2500S
(51" L.L. FOR SEPTIC, 60" FOR HOLDING, 72" MAX. DEPTH OF BURY, 1045 G.P.D.
WHEN USED AS A SEPTIC TANK BASED ON A 3 YR. SERVICE INTERVAL FOR
RESIDENTIAL WASTEWATER)
Product File No: 20060258

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of June 2011.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- An effluent filter must be installed in the wastewater stream from this product when this product is installed as a septic tank.
- The products produced by this manufacturer are approved to use the following:
 - Bolt on anodes.
 - One inch opening for electrical connections.
 - Internal support rings spaced evenly along tank.
 - Optional 6", 8", or 10" threaded plug in access cover.
 - Flip top access cover or bolt down cover with or without gasket.
 - 3", 4" or 6" diameter suction pump extension with coupling located at either end or in top of tank.
 - 2" opening for vent connection.
 - 4", 6" or 8" inlet and/or outlet.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20050888. The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov